



Certificate of Compliance

This certificate is issued for the following:

POLYETHYLENE PIPE

<i>Product Designation</i>	<i>O.D., Pipe Size, mm.</i>	<i>Pressure Rating, psi (kPa)</i>
Pipe, RDE(SDR)11	75, 90, 110, 160, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630, 710, 800	200 (1380)

Prepared for:

**Extrucol SA
Parque Industrial Km 3
Via Palenque
Bucaramanga, Santander
Columbia**

FM Approvals Class: 1613

The polyethylene pipe listed herein is FM Approved as of July 26, 2017

To verify the future Approval status of these products, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group